



# AGA CERTIFIED PRODUCT

Certificate Holder: **BONOMI INDUSTRIES SRL**

ABN/ACN No. (if applicable): N/A

Agent (if applicable): N/A

Type of Component: **Manual Shut-Off Ball Valve (Type 1)**  
*Temperature rating: 0 – 60°C*

Model No. & Description: **RUB**  
*(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)* **S84 – [F/F & M/F]**  
**NB 1/4", 3/8", 1/2", 3/4", 1", 1 1/4", 1 1/2", 2"**  
**(8, 10, 15, 20, 25, 32, 40, 50mm)**  
**MWP 2100kPa**

**S84 - [F/F & M/F]**  
**NB 2 1/2", 3" & 4"**  
**(65, 80, 100mm)**  
**MWP 1500kPa**

*Note: Various thread forms available in accordance to AS ISO 7.1*

Relevant Standard(s): **AS 4617 – 2018 (Including Amendment 2)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

**This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.

  
**Client Manager**

  
**Certificate Authorised**



Certificate first issued: **16 March 1995**

Certificate No: **5244**

This copy valid from: **02 September 2024**

Refer specification issue: **10**